



UNIVERSITY OF PENNSYLVANIA  
FACILITIES SERVICES  
3101 WALNUT STREET  
PHILADELPHIA, PENNA. 19104-6289


MASTER DETAIL  
HVAC DEPARTMENT

TITLE RESTRAINING METHOD FOR  
MECHANICAL JOINT VALVE


DATE  
08-01-12

REV DATE

FILE NO.



- COVER ASSEMBLY WITH POLYETHYLENE ENCASEMENT
- PLUG VALVE HYDRANT LID IN STREET AND AIR VENT HYDRANT LID IN SIDEWALK SHOULD BE LABELED CHWS AND RETURN



## CHILLED WATER AIR VENT HYDRANT DETAIL

SCALE: NTS